

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

11/5/2026

It is certified that an inspection team headed by Sri. V. Raja Rao, Senior Water Analyst

(Name of Officers with designation) from Regional Public Health Lab Guntur.

inspected the Ravindra Bharathi's Green school, Poranki.

(Name & Address of the school) on 6-5-2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 3209, 3210 dated 6-5-2026

of Regional public Health laboratory, Guntur. (PHED Lab) certified that

the Ravindra Bharathi's Green school. (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One year.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : Regional

Public Health Lab.

Guntur.

A.P.

To Ravindra Bharathi's Green school.

RS.NO. 471/3, Penamaluru Centre.

(Name & Address of the Institution)

Poranki, Tadigadapa Municipality.

Krishna District.

Note: The certificate is to be issued by authorized officer, PHED Lab / local bodies

Senior Analyst (Water)
Regional Laboratory
Medical College Campus
Guntur-4.



V. Sanythi

CORRESPONDENT

RAVINDRA BHARATHI'S GREEN SCHOOL,
BANDAR ROAD, PENAMALURU MANDAL,
PORANKI, YSR TADIGADAPA MUNICIPALITY,

KRISHNA DISTRICT-521137

CBSE AFFILIATION NO: 130613

P. Sujitha

PRINCIPAL

RAVINDRA BHARATHI'S GREEN SCHOOL,
BANDAR ROAD, Penamaluru Centre,
PORANKI, Krishna District-521 137

GOVERNMENT OF ANDHRAPRADESH
DIRECTORATE OF I.P.M.PH.LABS, FOOD (H) ADMN, Mangalagiri, Guntur.
REGIONAL PUBLIC HEALTH LABORATORY, GUNTUR

REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER

Sample from	Ravindra Bharathi's Green School, RSNo: 471/3, Penamaluru Center, Poranki, Tadigadapa Municipality, Krishna Dt.	Lab. Ref. No:	3209
		Collected on	06.05.2026
		Received on	06.05.2026
Collected by	Staff.	Source Profile	Ro Water

		Source / Sample	Limits as per IS 10500:2012	
		Drinking water tap in school.		
S. No	Parameter		Desirable (Acceptable limit)	Permissib le limit in the absence of alternativ e source
Physical Parameters				
1	Colour (Hazen units)	<5.0	5	15
2	Turbidity in NTUS``	0.1	1	5
3	Odour	Unobjectionable	Unobjectionable	Agreeabl e
4	pH	6.9	6.5 – 8.5	No relaxation
5	Conductivity at 25 °C (Micro Mhos/ Cm)	110	...	
6	TDS (mg/L)	72	500	2,000
Chemical parameters (mg/L)				
1	Alkalinity (as CaCO ₃)	Nil	...	
2	Total Alkalinity. Max	20	200	600
3	Total hardness max	24	300	600
4	Calcium hardness (as CaCO ₃)	12	..	
5	Magnesium hardness (as CaCO ₃)	12	..	
6	Calcium (as Ca)	5.0	75	200
7	Magnesium (as Mg)	3.0	30	100
8	Ammonical Nitrogen	Nil	...	
9	Nitrite (as N)	Nil	...	
10	Chloride (as Cl)	28	250	1,000
11	Fluoride (as F)	0.1	1	1.5
12	Iron (as Fe)	Nil	0.3	No relaxation

Remarks: The given sample physico chemically Satisfactory for drinking purpose as the analysed parameters are within the desirable limits.



P. Sujitha

PRINCIPAL
RAVINDRA BHARATHI'S GREEN SCHOOL
 Bandar Road, Penamaluru Centre,
 PORANKI, Krishna District-521 137

R. P. N. S.
Senior Analyst (Water)
Regional Laboratory
 Medical College Campus
 Guntur-4.

GOVERNMENT OF ANDHRA PRADESH
DIRECTORATE OF I.P.M., P.H.LABS, FOOD (H), ADMINISTRATION, Mangalagiri, Guntur
REGIONAL P.H.LABORATORY, MEDICAL COLLEGE CAMPUS, GUNTUR -4
REPORT OF MICROBIOLOGICAL ANALYSIS OF WATER

Sample(s) from: Ravindra Bharathi's Green School, RSNo: 471/3, Penamaluru Center,
Poranki, Tadigadapa Municipality, Krishna Dt.

Collected on: 06.05.2026

Received on : 06.05.2026

Paid / Free : paid

Collected by : Self.

S.No	Lab Ref. No	SOURCE	Residual Chlorine mg.per litre	MPN of Coliform Bacteria Per 100 ml.	Nature of Coliform Bacteria Isolated	MPN of Esch. coli.
1	3210	Drinking water tap Ro in school.	Nil	Nil	-	-

Remarks:- The given sample is bacteriologically satisfactory for drinking purpose as the evidenced by the Nil MPN count of coliform bacteria.



R. P. S. 8/5
Senior Analyst (Water)
Regional Laboratory
Medical College Campus
Guntur-4.

P. Sujitha

PRINCIPAL
RAVINDRA BHARATHI'S GREEN SCHOOL
Bandar Road, Penamaluru Centre
PORANKI, Krishna District-521 137

V. Sautli
CORRESPONDENT
RAVINDRA BHARATHI'S GREEN SCHOOL,
BANDAR ROAD, PENAMALURU MANDAL,
PORANKI, YSR TADIGADAPA MUNICIPALITY,
KRISHNA DISTRICT-521137
CBSE AFFILIATION NO: 130613